MANUAL MODE



In some start-up conditions may be useful to work in "hand" mode.

Power off theprocessor, press + key and keep it pressed giving power on:

HAnd message will be displayed (release now + key).

Push + until is displayed number required to be handed:

1 = HEAT relay, 2 = Alarm relay, 3 = VENTILATION 0-10V output, and push

ALARM for activing relay (or to pass from 0V to 10V on ventilation output).

Pushing again + for increase relay number previous relay is disactivated.

You can press ALARM for a least two seconds to escape and return to the Run Mode.

PRESET PROGRAMS (Bootstrap)



This processor is already programmed with the following (variable) settings. To return to these settings at any time you may:

Power off the processor, press **MAX VENT** key and keep it pressed giving power on: **boot** message will be displayed (release now **MAX VENT** key).

 $HEAt = 20.0^{\circ}$ $vEnt = 25.0^{\circ}$ $SP._{-} = 0$ $SP._{-} = 100$ $AL._{-} = 10.0^{\circ}$ $AL._{-} = 40.0^{\circ}$ COST value are shown in COST paragraph.

INSTALLATION

How to connect the line


Connect line on terminals **L-N**; protect supply with adeguate fuse.

How to connect the sensors

Connect the sensor provided as shown in the diagram. For remote connections use a standard 0.5-square millimeter two-pole wire, taking great care over the connections, by insulating and sealing the joins carefully. - O.C.- is displayed when the temperature sensor wiring is open, -S.C.- is displayed when the temperature sensor wiring is short circuit.

How to connect the contacts

Connect terminals on the terminal block (contacts up to 4AMP.AC1) to the loads as shown in the diagram.



* Other power voltage if you required

As it company policy to continually improve the products the Manufacturers reserve the right to make any modifications thereto without prior notice. They cannot be held liable for any damage due to malfunction.



HP70

SL 3.0 Ventilation proportional 0-10V

Handbook



MAIN SETTINGS (Run Mode)

HEAT TEMPERATURE SETTING.



Press **HEAT**:

This message will be displayed instead of the *Set Heat temperature value.

Press + or - to modify, press HEAT to exit.





VENTILATION TEMPERATURE SETTING.

Press °C VENT:

This message will be displayed instead of the *Set Ventilation temperature value (start first speed).


Press + or - to modify, press VENT to confirm.

At this point: this message will be displayed instead of the *Minimum Ventilation Speed* %.

Press + or - to modify, press VENT to confirm.

At this point: this message will be displayed instead of the *Maximum Ventilation Speed %*.

Press + or - to modify, press VENT to confirm.



ALARM PARAMETER SETTING.




Press ALARM:

This message will be displayed instead of the *Set Minimum Alarm temperature value.

Press + or - to modify, press ALARM to confirm.

At this point: this message will be displayed instead of the *Set Maximum Alarm temperature value.

Press + or - to modify, press ALARM to exit.



COSt PROGRAMMING (System constants)



These settings refer to the operation mode of the system and must be made on initial startup. Press - / + at the same time for at least one second: the message *C.O.S.t.* will be displayed.


Press than repeatedly **ALARM** until the message regarding the chosen variable is displayed (see table below): value of variable and message will be displayed. Press + or - to set a new value and then press **ALARM** to confirm.

The next system constant will then appear.

You can press ALARM for at least 2 seconds to exit and return to the Run Mode.

°C HEAT differential		
°C VENTILATION proportional band		
= 1 temperature representation (=1 °C, =2 °F)		
(+ or -)		

STATE INDICATIONS LAMP



In normal condition (not in programming) press **VENT** key for at least 1 second to display % speed insert.

VIEWING AMBIENT TEMPERATURE RECORDING

A	Press + :		will be displayed followed by
	_		°Maximum Temperature Recording.
4	Press -	1	: will be displayed followed by
			°Minimum Temperature Recording.

Values are permanently stored in the memory: for deleting all values in the memory keep pushed + key for more than 3 seconds: *CLEA* message will appear on display before clearing operation.

OPERATIVE DIAGRAMS

